



Recent Data Anomalies at USGS Site 01650800 Aug 2012 Sligo Creek near Maple Avenue

USGS Real-Time Data at this site

State standards: Temperature $\leq 32.2^{\circ}\text{C}$ Turbidity ≤ 150 NTU $6.5 \leq \text{pH} \leq 8.5$ Dissolved oxygen > 5.0 mg/l

Parameter	Date	Value
pH	2012-08-22 08:30	320
Dissolved Oxygen	2012-08-22 08:30	2.1
pH	2012-08-22 08:45	321
Dissolved Oxygen	2012-08-22 08:45	1.6
pH	2012-08-24 12:15	513
Dissolved Oxygen	2012-08-24 12:15	0.9
pH	2012-08-24 12:30	514
Dissolved Oxygen	2012-08-24 12:30	0.5
pH	2012-08-24 12:45	514
Dissolved Oxygen	2012-08-24 12:45	0.3
pH	2012-08-24 13:00	515